



## The City of Daytona Beach Utilities Department

To: James V. Chisholm, City Manager

From: Shannon Ponitz, Utilities Director *SP*

Date: October 1, 2018

Subject: Bethune Point Water Reclamation Facility Influent Pumps from Barney's Pumps –  
**Sole Source**

---

### **REQUEST:**

The Utilities Department requests the City Commission adopt a resolution authorizing a purchase from Barney's Pumps Inc., P.O. Box 56170, Jacksonville, FL 32241-6170, in the amount of \$70,590 for two influent pumps for the Bethune Point Water Reclamation Facility.

### **PURPOSE:**

The purpose of this request is to maintain compliance with State and Federal permits.

### **CONSIDERATION:**

The Bethune Point Water Reclamation Facility (WRF) utilizes three centrifugal pumps in parallel to move raw sewage from the influent wetwell to the treatment process. This purchase would replace one pump that has reached the end of its useful life and will provide a spare pump for emergencies or should any of the three pumps fail. Sole Source is being requested as Barney's Pumps is the sole distributor for Aurora Pumps. Aurora Pumps is the original pump manufacturer and the only pump that will bolt to the existing infrastructure without major structural modifications.

### **FUNDING:**

Sufficient funds are available in the following accounts:

425-610000-536-565000-611407 Renewal & Replacement 5%	\$21,193.05
425-610000-536-565000-611801 Renewal & Replacement 5%	\$49,396.95

### **RECOMMENDATION:**

The Utilities Department recommends the City Commission adopt a resolution authorizing a purchase from Barney's Pumps Inc., P.O. Box 56170, Jacksonville, FL 32241-6170, in the amount of \$70,590 for two influent pumps for the Bethune Point Water Reclamation Facility.

### **SCHEDULE:**

Upon Commission Approval 11-2018

### **ATTACHMENT(S):**

Agenda Summary  
Sufficiency of Funds  
Quote  
Sole Source Letter  
Power Point