

AGENDA SUMMARY

The City of Daytona Beach

DEPARTMENT/DIVISION: Utilities Department STAFF CONTACT: Shannon T. Ponitz, P.E. ITEM TITLE: Resolution for two influent pumps at Bethune Point WRF – Barney's Pumps – Sole Source	Meeting Date: Nov. 7, 2018 First Agenda Action: Nov. 7, 2018 Second Agenda Action:
--	---

ACTION (check one): Presentation Discussion Resolution Ordinance
 Resolution – PUBLIC HEARING Ordinance on first reading – PUBLIC HEARING

IS ITEM BUDGETED: YES NO BUDGET \$ N/A
 TOTAL COST \$ \$70,590

VISION PLAN/STRATEGIC PLANNING INITIATIVE: Maintaining and Improving Infrastructure

BACKGROUND: The Utilities Department requests the City Commission adopt a resolution authorizing a purchase from Barney's Pumps Inc., P.O. Box 56170, Jacksonville, FL 32241-6170, in the amount of \$70,590 for two influent pumps for the Bethune Point Water Reclamation Facility.

The purpose of this request is to maintain disinfection as required in State and Federal permits.




The Bethune Point Water Reclamation Facility (WRF) utilizes three centrifugal pumps in parallel to move raw sewage from the influent wetwell to the treatment process. This purchase would replace one pump that has reached the end of its useful life and will provide a spare pump for emergencies or should any of the three pumps fail. Sole Source is being requested as Barney's Pumps is the sole distributor for Aurora Pumps. Aurora Pumps is the original pump manufacturer and the only pump that will bolt to the existing infrastructure without major structural modifications.

Sufficient funds are available in the following accounts:

425-610000-536-565000-611407 Renewal & Replacement 5%	\$21,193.05
425-610000-536-565000-611801 Renewal & Replacement 5%	\$49,396.95

STAFF/BOARD RECOMMENDATION: The Utilities Department recommends the City Commission adopt a resolution authorizing a purchase from Barney's Pumps Inc., P.O. Box 56170, Jacksonville, FL 32241-6170, in the amount of \$70,590 for two influent pumps for the Bethune Point Water Reclamation Facility.

REVIEWED BY AS REQUIRED:

DEPT./DIVISION HEAD	PURCHASING	LEGAL	CITY MANAGER
 DATE: <u>10/1/18</u>	<div style="border: 1px solid black; background-color: #e0f0e0; padding: 2px; text-align: center; margin-bottom: 5px;"> APPROVED <small>By FlickJoanne at 2:32 pm, Oct 02, 2018</small> </div> DATE: _____	 DATE: <u>10/1/18</u>	 DATE: _____