

# AGENDA SUMMARY

## The City of Daytona Beach

<b>DEPARTMENT/DIVISION:</b> Public Works/ Technical Services <b>STAFF CONTACT:</b> Joe Piper, Project Manager <b>ITEM TITLE:</b> Approval of quote with A.F Standby Systems, 5570 Florida Mining Blvd Ste 210 Jacksonville, FL 32257, to provide a new 60KW Generator and new 400 AMP Transfer Switch for Fire Station 6.	<b>Meeting Date:</b> 2/12/2019  First Agenda Action:  Second Agenda Action:
--	---

**ACTION** (check one): Presentation  Discussion  Resolution  Ordinance   
 Resolution – PUBLIC HEARING  Ordinance on first reading – PUBLIC HEARING





**IS ITEM BUDGETED:** YES  NO  BUDGET \$ 35,200.00  
 TOTAL COST \$ \$35,200.00

**VISION PLAN/STRATEGIC PLANNING INITIATIVE:** This project will expand the service capabilities of the Fire Department to be able to respond during emergency operations for weather events such as hurricanes. This expansion will allow for the station to respond to surrounding new development.

**BACKGROUND:** The Fire Department has requested an <sup>INCREASE IN CAPACITY</sup> of the generator and automated switch gear at FS #6 to provide emergency power service to the entire firehouse. This project will expand the service capabilities of the Fire Department to be able to respond to surrounding new development. This project also allows for continuous emergency operations and as a backup staging area during emergency events such as hurricanes. This expansion allows for a greater number of Fire Stations to remain in service during an emergency event to meet the growing demand from population and business communities. FS #6 was abandon during the last storm due to losing power.

**STAFF/BOARD RECOMMENDATION:** The Public Works Director is recommending that the City Commission approve the quote with A.F Standby Systems for \$35,200.00 for supplying the new 60 KW generator and 400 AMP transfer switch for Fire Station 6.

**REVIEWED BY AS REQUIRED:**

DEPT./DIVISION HEAD	PURCHASING	LEGAL	CITY MANAGER
  DATE: <u>1/3/2019</u>	  DATE: <u>1/7/19</u>	  DATE: <u>1/7/19</u>	  DATE: _____

Please have quote revised per my email  
